

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20140323-E132659  
**Report Reference** E132659-20080520  
**Issue Date** 2014-March-23

**Issued to:** LENZE AUTOMATION GMBH  
HANS LENZE STR 1  
31855 AERZEN, GERMANY


**This is to certify that  
representative samples of** POWER CONVERSION EQUIPMENT  
See Addendum Page

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.


**Standard(s) for Safety:** UL 508C, Power Conversion Equipment  
CAN/CSA C22.2 no. 14-13, Industrial Control Equipment

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)




# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20140323-E132659  
**Report Reference** E132659-20080520  
**Issue Date** 2014-March-23

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USL, CNL – Power Conversion Equipment, Series E84, modular system, consisting of:

- Inverter Unit, open type, Cat. No. E84AV, followed by S, H, T or T, followed by letter, followed by D or E, followed by 181, 251, 371, 551, 751, 112, 152, 222, 302, may be followed by numbers and/or letters.
- Communication Modules, Cat. No. E84AYC, followed by PM, ET, IB, ER, EC, EO or ES may be followed by numbers or letters.
- Memory Modules, Cat. No. E84AYM, followed by 1 or 2 or 3, followed by numbers or letters.
- Distributor for Master Frequency, Cat. No. EZAEVA, followed by numbers.



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

